

Architecture Plus, Inc. • July 01, 2020 @ 4:14pm • File located @ P:\2019\19-21 Foreman School District - New High School\Architecture\19-21_A1.2B.dwg • Created by: gerfenna@archplusinc.net

REFLECTED CEILING LEGEND

2x4 RECESSED MOUNTED FLUORESCENT LIGHT FIXTURE (FOR EMERGENCY LIGHTING SEE ELECTRICAL).

FLUORESCENT STRIP LIGHT

DECORATIVE PENDANT LIGHT FIXTURE

STRIP FIXTURE ABOVE

PENDANT LIGHT FIXTURE

CEILING MOUNTED EXIT LIGHT

WALL MOUNTED EXIT LIGHT

WALL SCONCE

RECESSED CAN LIGHT

WALL MOUNTED LIGHT FIXTURE

WALL PACKS

SUPPLY AIR GRILL

RETURN GRILLE

SMALL RETURN AIR GRILL

EXHAUST FAN

RETURN AIR GRILL

OUTSIDE AIR DIFFUSER

ROUND AIR DIFFUSER

METAL SOFFIT PANEL

ACOUSTICAL TILE & GRID

SUSPENDED GYPSUM BOARD CEILING

FURROWDOWN

SMOKE DETECTOR

HORN/STROBE STATION

PULL STATION

OCCUPANCY SENSORS

REMOTE FIRE ALARM PANEL


FIRE ALARM CONTROL PANEL

EMERGENCY LIGHTS


CEILING ELEVATION ALIGN

SOUND ATTENUATION BLANKET ABOVE CEILING

SEE ELECTRICAL & MECHANICAL SHEETS FOR ADDITIONAL INFORMATION




1 REFLECTED CEILING PLAN - AREA 'B'
SCALE: 1/8" = 1'-0"




A ACCORDION DOOR HEADER DETAIL BASIS OF DESIGN: WGN-DOOR CORPORATION
SCALE: 1 1/2" = 1'-0"

REFLECTED CEILING PLAN GENERAL NOTES

1. ALL SPRINKLER HEADS, RECESSED LIGHTS, AND SMOKE DETECTORS SHALL BE CENTERED IN ACOUSTICAL CEILING TILES UNLESS NOTED OTHERWISE.
 2. ALL SUSPENDED ACOUSTICAL CEILING TILE SHALL BE TYPE AND COLOR AS SHOWN IN THE FINISH SCHEDULE AND SPECIFICATIONS. ACT "A" IS TYPICAL WHERE ACT IS INDICATED UNLESS NOTED OTHERWISE.
 3. ALL CEILING GRIDS SHALL BE CENTERED IN THE ROOM EXCEPT WHERE SPECIFICALLY NOTED OTHERWISE.
 4. GYPSUM BOARD CEILINGS WHERE OCCUR SHALL BE 5/8" TYPE "X" ON SUSPENDED METAL FRAMING WITH HAT CHANNELS AT 16" O.C. UNLESS NOTED OTHERWISE.
 5. MECHANICAL GRILLES AND DIFFUSERS INDICATED ON REFLECTED CEILING PLANS ARE FOR COORDINATION PURPOSES ONLY. SEE MECHANICAL DRAWINGS FOR EXACT TYPES AND QUANTITIES.
 6. FIRE DAMPERS ARE REQUIRED IN ALL DUCTS WHICH PENETRATE FIRE RESISTIVE ASSEMBLIES.
 7. REFER TO LS1.2 FOR ROOMS TO RECEIVE ONE-HOUR GYPSUM BOARD CEILING.
 8. CEILING SUBCONTRACTOR SHALL PROVIDE BLOCKING AND TEES SURROUNDING MECHANICAL GRILLES AND DIFFUSERS.
 9. PROVIDE CEILING ACCESS PANELS IN GYPSUM BOARD CEILINGS WHERE REQUIRED FOR ACCESS ABOVE THE CEILING.
 10. CEILING HEIGHTS ARE AS NOTED ON THE ENLARGED REFLECTED CEILING PLANS AND ARE MEASURED FROM THE FINISH FLOOR OF THE SPACE UNLESS NOTED OTHERWISE.
 11. SEE SHEET F1.1A AND F1.2B/C FOR GYPSUM BOARD FURR DOWN PAINT COLORS.
- NOTE: THESE RCP GENERAL NOTES APPLY TO ALL REFLECTED CEILING PLAN SHEETS. SEE ENLARGED RCP'S SHEETS FOR ADDITIONAL INFORMATION



FOREMAN SCHOOL DISTRICT
NEW HIGH SCHOOL
FOREMAN, ARKANSAS



ARCHITECTURE PLUS, INC.
907 South 21st Street Fort Smith, Arkansas 479-783-8395



REFLECTED CEILING PLAN - AREA 'B'

REVISIONS:

PROJECT: 19-21

DATE: 06-30-2020

A1.2B



ARCHITECTS • PLANNERS